



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Clifford Terrace 50, Kensington
50 Clifford Terrace Kensington
Contract No: P3494

Callouts:

Date of Call: 15-12-2018 19:34:00
Time of Arrival: 15-12-2018 22:45:00
Rectification Time: 15-12-2018 22:45:00
Time of Departure: 15-12-2018 23:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): b

Call Description: Ooo doors open

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Vandalism

Work Action (CORRECTION): Clean Light Ray

Work Description: Light ray ripped off\r\nRemounted temporarily need access to store tomorrow for supplies to remount if comes in ooo again

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer