



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Gurewicz Building, Moshin Building
10-12 Balaclava Rd St Kilda
Contract No: B3376

Callouts: 22759

Date of Call: 02-01-2019 13:21:08
Time of Arrival: 02-01-2019 15:10:00
Rectification Time: 02-01-2019 15:15:00
Time of Departure: 02-01-2019 15:38:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): g

Call Description: when lift is called. doors open but there is no lift. \r\nGELC sensor on lift not working

Order Number: 24870

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): Clean Light Ray

Work Description: Lift reported opening to not lift, this is impossible due to the door motor being on the lift can and will only be able to open landing doors when floor. Tested lift also whipped down livht ray due to sand build up \r\nTested lift all okay

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

Adrianna 9522 8222