



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel  
131 King St Melbourne  
Contract No: P3249

## Callouts:

Date of Call: 09-12-2018 9:05:00  
Time of Arrival: 09-12-2018 9:15:00  
Rectification Time: 09-12-2018 9:25:00  
Time of Departure: 09-12-2018 9:40:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** S.W.P

**For Lift(s):** 1

**For Floor(s):** 6

**Call Description:** Lift 1 s.w.p

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Printed Circuit Board Faulty

**Work Action (CORRECTION):** See Work description

**Work Description:** Released passanger. Lift 1 shut down due to board issue

**Part Required:** No Parts Required

**Service Technician**

Brad Stellini

**Report Customer**

.