



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts ID: 22102

Date of Call: 25-10-2018 13:04:52
Time of Arrival: 25-10-2018 15:00:00
Rectification Time: 25-10-2018 15:40:00
Time of Departure: 25-10-2018 15:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: Lift 1 is stuck on ground floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: main switch tripped at main switch board \r\nreset, checked controller operation,\r\nntested ok.\r\n

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Chakshu 0433271212