



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Elizabeth St 65, Melbourne
65 Elizabeth St Melbourne
Contract No: P3131

Maintenance ID:

Date of Call: 18-10-2018
Time of Arrival: 0:00:00
Time of Departure: 0:00:00

Maintenance Details

Maintenance Description: routine service
phone in lift not working please contact service provider.
motor room lights not all working need to replace
faulty lights notified building management.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Check pit equipment and check water for pit	Y
Safety gear full performance test	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Robert Pelle

Customer Email

FrankO@selectocm.com.au