



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Gordon St 127, Footscray  
127 Gordon St Footscray  
Contract No: P3469

## Callouts:

Date of Call: 21-12-2018 19:25:00  
Time of Arrival: 21-12-2018 20:05:00  
Rectification Time: 21-12-2018 20:20:00  
Time of Departure: 21-12-2018 20:30:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** g

**Call Description:** Lift 2 ooo on ground with doors open

**Order Number:** 16319

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Fuse Blown

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift 2 ooo on ground, found cp2 RCD tripped, found on level six a dog had we\ed in the sill and down the shaft causing the locks on 5 to get  
\r\nReset RCD and tested lift operation, will cause on going problem if dog/owner is not found and made aware

**Part Required:** No Parts Required

**Service Technician**

Dwain Sanderson

**Report Customer**

.