



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Temple Court
422 Collins St Melbourne
Contract No: P3327

Callouts:

Date of Call: 08-12-2018 9:32:00
Time of Arrival: 08-12-2018 10:20:00
Rectification Time: 08-12-2018 10:30:00
Time of Departure: 08-12-2018 10:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): 5

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift at floor level ooo displaying es\r\nmachfault on main board display\r\nSafety, lock, car and door circuit leds all in correct state\r\nCleared machfault error and test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer