



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 07-11-2018 10:15:00
Time of Arrival: 07-11-2018 10:15:00
Rectification Time: 07-11-2018 11:00:00
Time of Departure: 07-11-2018 11:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): G

Call Description: Lift Shutdown due to water ingress

Order Number: 15413

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Cleaned excess moisture from doors, check car boards and COP. Ran to test.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Jacobs