

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Barkly St 250, Footscray
250 Barkly St Footscray
Contract No: P3309

Callouts: 22440

Date of Call: 29-11-2018 15:49:51 Time of Arrival: 29-11-2018 16:15:00 Rectification Time: 29-11-2018 16:20:00 Time of Departure: 29-11-2018 16:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2

For Floor(s): c6

Call Description: SWP

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Released passengers \r\nErr44 on drive and drive error logged on main board fault history\r\n

Part Required: No Parts Required

Service Technician Report Customer

Matt Grieger Brendan 0431 432 452