



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Blackwood St 4-12
4-12 Blackwood St North Melbourne
Contract No: P3105

Callouts: 22683

Date of Call: 20-12-2018 16:32:16
Time of Arrival: 20-12-2018 5:10:00
Rectification Time: 20-12-2018 19:15:00
Time of Departure: 20-12-2018 7:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): G

Call Description: stuck open on ground floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: ALR contactor faulty cleaned and replaced contacts

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

Vicky - 0413 459 259