



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Aldi

313 Doncaster Road North Balwyn

Contract No: P3730

Callouts: 22651

Date of Call: 18-12-2018 10:07:00

Time of Arrival: 18-12-2018 10:26:00

Rectification Time: 18-12-2018 11:07:00

Time of Departure: 18-12-2018 11:12:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): b1

Call Description: out of order.

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Water logged door lock. Client advised water had flooded premises. Evidence of water in shaft also around doors.. debris caught in door lock.
Dried out components and returned to service

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Targartha 03 9857 6617