



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton  
141 Nicholson St Carlton  
Contract No: P3118

## Callouts:

Date of Call: 22-11-2018 20:45:00  
Time of Arrival: 22-11-2018 21:30:00  
Rectification Time: 22-11-2018 21:55:00  
Time of Departure: 22-11-2018 22:05:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Closed

**For Lift(s):** 2

**For Floor(s):** 13

**Call Description:** O.o.o

**Order Number:** 15743

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Obstruction in doors

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Debris caught in lock contact. Remove and test lock alignment

**Part Required:** No Parts Required

**Service Technician**

mat tehan

**Report Customer**

.