



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Tower 3**

70 Lorimer Street Docklands

Contract No: P3671

**Callouts: 22248**

Date of Call: 09-11-2018 13:19:19

Time of Arrival: 09-11-2018 14:00:00

Rectification Time: 09-11-2018 15:00:00

Time of Departure: 09-11-2018 15:10:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Noisy

**For Lift(s):** W2

**For Floor(s):** .

**Call Description:** lift 2 is creaking on a regular basis when taking off & stopping

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Adjusted roller guides ran and tested

**Part Required:** No Parts Required

**Service Technician**

Brad Stellini

**Report Customer**

.