



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Brunswick St 150, Fitzroy**  
150 Brunswick St Fitzroy  
Contract No: P3511

**Callouts: 22420**

Date of Call: 28-11-2018 10:00:39  
Time of Arrival: 28-11-2018 10:30:00  
Rectification Time: 28-11-2018 10:52:00  
Time of Departure: 28-11-2018 10:56:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 2

**For Floor(s):** #

**Call Description:** lift 2 showing x on floor level sign and not in operation

**Order Number:** 007124

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Door held open 5 consecutive times on level 3 causing error148 door deviation. Increased door dwell time to 3 minutes

**Part Required:** No Parts Required

**Service Technician**

Marek Torrico

**Report Customer**

#