

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 03 9687 9099 info@unitedlifts.com.au

Customer Details:
Tower 3
70 Lorimer Street Docklands
Contract No: P3671

Maintenance:

Date of Call: 27-11-2018 Time of Arrival: 12:50:00 Time of Departure: 14:40:00

Maintenance Details

Maintenance Description: Routine maintenance \r\nElu test lifts 1 2 and 3

| Maintenance Task | W1 | W2 | W3 |
|---------------------------------------------------------------|----|----|----|
| Contact Building Rep. Check Ride & Appointments. | Y | Y | Y |
| Test all car safties | Y | Y | Y |
| Clean & Check all M/R Equipment | Y | Y | Y |
| Clean out controller ad check operation of various parts. | Y | Y | Y |
| Check tuning ajustments | Y | Y | Y |
| Check car door operator and associated equipment. | Y | Y | Y |
| Clean & check landing door equipment | Y | Y | Y |
| Check car top safeties, Ropes, Inductors Lubricate Rails Etc. | Y | Y | Y |
| Check and ajust car & cwt guide shoes | Y | Y | Y |
| Check all safety switches, limits in lift well | Y | Y | Y |
| Check pit equipment and check water for pit | Y | Y | Y |
| Test Lift Communications | Y | Y | Y |

Service Technician

Customer Email

Brad Stellini

 $steve @\, scaowners corp. com. au$