



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

PNBS

1-17 Potter Street Craigieburn

Contract No: P3628

Callouts: 22238

Date of Call: 08-11-2018 13:27:40

Time of Arrival: 08-11-2018 15:17:00

Rectification Time: 08-11-2018 16:17:00

Time of Departure: 09-11-2018 16:21:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 1

Call Description: lift is out of on level 1

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Level 1 door not closing due to lock issue. Adjusted locking mechanism and increased tension on door

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#