



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Victoria Hotel
215 Lt Collins St Melbourne
Contract No: P3234

Callouts:

Date of Call: 08-12-2018 11:09:00
Time of Arrival: 08-12-2018 11:40:00
Rectification Time: 08-12-2018 11:40:00
Time of Departure: 08-12-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 7

For Floor(s):

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: Passengers out at 1110am and lift running but wanted to still come out to check lift\r\nLast logged error 2 door lock fault \r\nCheck all door l
running clearances and make\r\nAll ok test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer