



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Temple Court
422 Collins St Melbourne
Contract No: P3327

Callouts: 22538

Date of Call: 10-12-2018 10:11:41
Time of Arrival: 13-12-2018 13:25:00
Rectification Time: 13-12-2018 13:55:00
Time of Departure: 13-12-2018 14:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 4

For Floor(s): .

Call Description: noisy rollers

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Adjusted rollers on lift 4 checked operation tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

cyrire