

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Nicholas Building
37 Swanston St Melbourne
Contract No: 3265

Callouts: 22346

Date of Call: 20-11-2018 10:35:09 Time of Arrival: 20-11-2018 11:30:00 Rectification Time: 20-11-2018 12:10:00 Time of Departure: 20-11-2018 12:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 2

For Floor(s): G

Call Description: Does not know lift number, just that it is the middle lift. stuck on ground floor with doors opening and closing

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Doors out of mesh on ground floor repositioned doors and checked

Part Required: No Parts Required

Service Technician Report Customer

Graeme Gathercole Serina 0418145749