



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Wangaratta St 13, Richmond  
13 Wangaratta St / 71 Tanner Richmond  
Contract No: P3232

## Callouts:

Date of Call: 08-12-2018 10:22:00  
Time of Arrival: 08-12-2018 11:05:00  
Rectification Time: 08-12-2018 11:05:00  
Time of Departure: 08-12-2018 11:25:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 1

**Call Description:** Ooo doors open

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** Clean Light Ray

**Work Description:** Light ray detecting obstruction in doors\r\nLooks that light ray been hit as has signs of damage \r\nRefix light ray to door and wipe down light rays\r\nTest ok

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**