



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Ormond St 94, Kensington
94 Ormond St Kensington
Contract No: P3421

Callouts: 22150

Date of Call: 31-10-2018 13:41:22
Time of Arrival: 31-10-2018 14:30:00
Rectification Time: 31-10-2018 14:49:00
Time of Departure: 31-10-2018 14:59:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): 11

Call Description: Lift 2 stuck with doors open on level 11

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift doors timed out of service. Checked door operation and door locks aswell as runners.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Allen 0426 155 405