



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Lt Collins St 390, Melbourne  
390 Lt Collins St Melbourne  
Contract No: P3218

**Callouts: 22198**

Date of Call: 05-11-2018 12:49:35  
Time of Arrival: 05-11-2018 13:24:00  
Rectification Time: 05-11-2018 13:49:00  
Time of Departure: 05-11-2018 14:21:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Noisy

**For Lift(s):** 1

**For Floor(s):** 3-5

**Call Description:** lift is making a banging sound between level 2 & 3, also level 3 says it's level 2

**Order Number:** #

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Observed bely roller noisy. Adjusted to suit. Observed car rail DBG requires adjusting. Fowarded to superior for requirements. Checked floor display and all ok.

**Part Required:** No Parts Required

**Service Technician**

Marek Torrico

**Report Customer**

Lauren