

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Melrose St 159, North Melbourne
159 Melrose St North Melbourne
Contract No: P3429

Callouts:

Date of Call: 03-11-2018 20:07:00 Time of Arrival: 03-11-2018 20:38:00 Rectification Time: 03-11-2018 21:03:00 Time of Departure: 03-11-2018 21:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 5

Call Description: out of order

Order Number: 15418

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: obstruction on level 5 landing doors \r\nremoved obstruction in track returned lift back to service

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Carly