



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Tower 3

70 Lorimer Street Docklands

Contract No: P3671

Callouts ID: 22107

Date of Call: 25-10-2018 16:22:36

Time of Arrival: 25-10-2018 16:28:00

Rectification Time: 25-10-2018 16:29:00

Time of Departure: 25-10-2018 16:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): W3

For Floor(s): 3

Call Description: person stuck in lift

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): Check Operation

Work Description: Door on level 3 car park not closed causing wind issue.

Part Required: No Parts Required

Service Technician

Daniel Barry

Report Customer

Nigel 0428 339 660