



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Brunswick St 150, Fitzroy
150 Brunswick St Fitzroy
Contract No: P3511

Callouts:

Date of Call: 25-11-2018 0:18:00
Time of Arrival: 25-11-2018 2:05:00
Rectification Time: 25-11-2018 2:50:00
Time of Departure: 25-11-2018 2:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 7

Call Description: reported lift 1 out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift 2 out of order on level 7\r\nerror 148 \r\nchecked safety on car and doors on level 7\r\nreset checked operation lift back in service

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Tiffany vivas