



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Breakfree Heritage Hotel
318 Lt Bourke St Melbourne
Contract No: P3282

Callouts:

Date of Call: 04-11-2018 17:07:00
Time of Arrival: 04-11-2018 19:05:00
Rectification Time: 04-11-2018 19:40:00
Time of Departure: 04-11-2018 19:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground

Call Description: lift out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: lift reported stuck on ground floor \r\ndoors open,\r\nlift was reset by reception staff,\r\nlift running on arrival checked error log no new logs recorded,\r\nchecked light ray, ground floor landing doors and car buttons,\r\nntested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Gabriella