



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wellington Street 240, Collingwood
240 Wellington Street Collingwood
Contract No: 3700

Callouts ID: 22118

Date of Call: 26-10-2018 13:33:22
Time of Arrival: 26-10-2018 14:00:00
Rectification Time: 26-10-2018 15:25:00
Time of Departure: 26-10-2018 15:43:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 11

Call Description: lift is out of order on level 11

Order Number: 15336

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift in fault on arrival. Governor slack rope tripped. Checked operation of slack rope and reset. Rubbish in pit around governor potentially got caught in rope switch. Checked operation of lift. All ok.

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

Security informed