



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Jones Lang LaSalle
401 Collins St Melbourne
Contract No: P3216

Callouts: 22475

Date of Call: 04-12-2018 10:13:42
Time of Arrival: 04-12-2018 10:25:00
Rectification Time: 04-12-2018 12:00:00
Time of Departure: 04-12-2018 13:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 9

Call Description: Service Lift: stuck with person\r\nLift Phone: 0498 789 524

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 3 stopped 400mm below level 9 lift was traveling from level 1 with 1 passenger, \r\nerror 20 checked possible causes\r\nchecked 1st slowdown switch ok,\r\nreturned lift back to service monitoring fault.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Saju (JLL) 0435738090