



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Clayton Hotel
319 Clayton Road Clayton
Contract No: B3738

Callouts ID:

Date of Call: 18-10-2018 22:59:00
Time of Arrival: 18-10-2018 23:40:00
Rectification Time: 19-10-2018 1:10:00
Time of Departure: 19-10-2018 1:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Main Circuit Braker Tripped

Work Action (CORRECTION): See Work description

Work Description: Lift ooo top floor \r\nWon't drive down \r\nSuspect faulty drive \r\nShut down overnight

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer