



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Dandenong
Metro Foster Street Dandenong
Contract No: W3677

Callouts:

Date of Call: 04-01-2019 18:33:00
Time of Arrival: 04-01-2019 19:05:00
Rectification Time: 04-01-2019 19:50:00
Time of Departure: 04-01-2019 20:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): G

Call Description: Platform 1 and 2 lifts not working.

Order Number: 660840

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Error 54. Door lock not dropping. Adjusted aircord cable. Straightened bent door shoe.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x