



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glen Eira Town Hall

0 Corner Hawthorn Rd & Glen Eira Rd Caulfield

Contract No: P3399

Callouts: 22700

Date of Call: 24-12-2018 10:33:30

Time of Arrival: 24-12-2018 11:10:00

Rectification Time: 24-12-2018 13:25:00

Time of Departure: 24-12-2018 13:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 5

For Floor(s): 1

Call Description: platform lift at library is out of order.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Strip and Rebuild

Work Description: Lift 5 was stopped on level one, found bottom limit switches were shorting to earth, found all limit switches in pit were full of water, emptied switches and cleaned contacts and reinstated
Tested lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

David Hipsher - 0447 523 941