



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Spring Road 12, Malvern
12 Spring Road Malvern
Contract No: P3743

Callouts:

Date of Call: 06-11-2018 11:54:00
Time of Arrival: 07-11-2018 0:45:00
Rectification Time: 07-11-2018 1:10:00
Time of Departure: 07-11-2018 1:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 2

For Floor(s): b

Call Description: Water going in lift shaft

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Pump in carpark basement failed to restart during power loss \r\nCar park had some flooding with water running off into lift shaft\r\nWater in
pit - gov ider sheave and switch under water along with pit gpo and light\r\nShut down and parked lift away from bottom floor

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer