



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

PEQ

135 Donnybrooke Road Mickleham

Contract No: W3654

## Maintenance:

Date of Call: 31-10-2018

Time of Arrival: 10:00:00

Time of Departure: 14:00:00

### Maintenance Details

**Maintenance Description:** Routine maintenance. Test Elu and emergency phone. Assist KD Fisher with air monitoring service.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Clean lift well equipment	Y
Fire Service Operation Test	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

**Service Technician**

mat tehan

**Customer Email**