



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Patterson Rd 60-66, Bentleigh  
60-66 Patterson Rd Bentleigh  
Contract No: P3247

**Callouts: 22645**

Date of Call: 17-12-2018 13:50:02  
Time of Arrival: 18-12-2018 13:00:00  
Rectification Time: 18-12-2018 13:00:00  
Time of Departure: 18-12-2018 13:30:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Playing Up

**For Lift(s):** 1

**For Floor(s):** G

**Call Description:** doors are closing really quickly

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Running On Arrival

**Work Action (CORRECTION):** See Work description

**Work Description:** Tested lift doors on all floors 4 times each level. Door speeds are normal, door slow down at end of close cycle normal. No faults found.

**Part Required:** No Parts Required

**Service Technician**

Kevin Wilkins

**Report Customer**

cythnia 0395574352