



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Doncaster Rd 651, Doncaster
651 Doncaster Rd Doncaster
Contract No: P3483

Callouts: 22137

Date of Call: 30-10-2018 14:24:00
Time of Arrival: 30-10-2018 15:00:00
Rectification Time: 30-10-2018 16:02:00
Time of Departure: 30-10-2018 16:14:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Jerking

For Lift(s): 1

For Floor(s): G

Call Description: lift is shuddering while traveling to ground floor

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift down contactor coil required replacing.\r\n

Part Required: 1 x 30kw 3 ph contactor

Service Technician

Marek Torrico

Report Customer

#