



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts ID:

Date of Call: 17-10-2018 7:45:00
Time of Arrival: 17-10-2018 7:50:00
Rectification Time: 17-10-2018 8:20:00
Time of Departure: 17-10-2018 8:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: Lift 1 o.o.o on level 3

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Drive fault checked associated circuit reset ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.