



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Depot
98 QUEENS AVE CAULFIELD EAST
Contract No: P3634

Callouts ID: 21995

Date of Call: 15-10-2018 14:11:30
Time of Arrival: 15-10-2018 14:40:00
Rectification Time: 15-10-2018 16:00:00
Time of Departure: 15-10-2018 16:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: roller beasring fallen out. Ourt oof order

Order Number: 656801

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door lock out of adjustment causing door lock roller to break. Adjusted lock and replaced roller ran and tested ok

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

Site contact: Collin 0499 909 034