



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Faversham House
27 Shierlaw Ave Canterbury
Contract No: P3200

Callouts ID:

Date of Call: 29-10-2018 3:15:00
Time of Arrival: 29-10-2018 8:15:00
Rectification Time: 29-10-2018 8:30:00
Time of Departure: 29-10-2018 9:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): 1

Call Description: Lift has recorded power interruption message

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Reset Control System

Work Description: Message consistent with phone unit losing power, also found elu (emergency light unit) tripped. Reset unit and test ok. No message played on arrival. Tested lift and returned to service. Possible power interruption issue. Tech was advised last night staff were happy to attend call this morning.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0