



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wyndham Vale Train Station
36 Eureka Dr Wyndham Vale
Contract No: 3611

Callouts:

Date of Call: 15-12-2018 8:24:00
Time of Arrival: 15-12-2018 9:35:00
Rectification Time: 15-12-2018 9:45:00
Time of Departure: 15-12-2018 9:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

For Lift(s): 1,2

For Floor(s):

Call Description: No lights in both lifts after blackout/storm

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Power Failure

Work Action (CORRECTION): Power Failure Reset

Work Description: Both car light and power rcd tripped during storm/power surge\r\nReset and check for any signs of water entry \r\nAll ok and working

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer