



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts ID: 22099

Date of Call: 25-10-2018 9:54:54
Time of Arrival: 25-10-2018 12:00:00
Rectification Time: 25-10-2018 14:30:00
Time of Departure: 25-10-2018 14:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): .

Call Description: lift is out of order, nothing on display and lift not calling

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: supplied and fitted new power supply 24v and 5v\r\nadjusted ground floor level\r\nperformed new learn run\r\nchecked power supply voltages\r\nrun and tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Jeremy