



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glenhuntly Rd 242, Elsternwick
242 Glenhuntly Rd Elsternwick
Contract No: P3449

Callouts: 22405

Date of Call: 26-11-2018 16:54:27
Time of Arrival: 26-11-2018 17:20:00
Rectification Time: 26-11-2018 17:40:00
Time of Departure: 26-11-2018 17:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 1

Call Description: lift is out of order

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Door Operator

Work Description: Found car doors open approx 25mm while landing doors had closed on level 1. Suspect door operator fault. Cleaned door tracks, lubricated d mechanism. Closed car doors and reset door operator. Returned to service, tested ok.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*