



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elizabeth St 191, Richmond (Building B)
191 Elizabeth St Richmond (Building B)
Contract No: P3547

Callouts:

Date of Call: 29-12-2018 7:49:00
Time of Arrival: 29-12-2018 8:20:00
Rectification Time: 29-12-2018 11:20:00
Time of Departure: 29-12-2018 11:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): B

Call Description: Passenger stuck in lift.

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Over voltage trip error on inverter. \r\nReleased passenger. Lift shutdown for further investigation.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x