



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

ACU

115 Victoria Parade Fitzroy

Contract No: B3045

Callouts:

Date of Call: 13-11-2018 20:51:00

Time of Arrival: 14-11-2018 8:55:00

Rectification Time: 14-11-2018 9:55:00

Time of Departure: 14-11-2018 10:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s):

For Floor(s): 2

Call Description: Lift stuck with passanger lvl 2

Order Number: #

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: Fault drive contactor. Replaced and returned to service

Part Required: 1 x 30kw 3ph contactor and 2no 2nc auxiliarys

Service Technician

Marek Torrico

Report Customer

#