



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington  
56 Derby St Kensington  
Contract No: P3419

## Callouts:

Date of Call: 25-12-2018 12:30:00  
Time of Arrival: 25-12-2018 13:00:00  
Rectification Time: 25-12-2018 13:05:00  
Time of Departure: 25-12-2018 13:25:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 2

**Call Description:** Ooo

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Faulty Contactor

**Work Action (CORRECTION):** Replace/Repair Reply or Contactor

**Work Description:** Mlt error displayed\r\nWire broken from crimped lug in terminal on Auxillary block of main contactor\r\nRewire and test operation

**Part Required:** No Parts Required

**Service Technician**

Matt Grieger

**Report Customer**