

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Queen St 39, Melbourne
39 Queen St Melbourne
Contract No: P3542

Callouts: 22284

Date of Call: 14-11-2018 12:36:23 Time of Arrival: 14-11-2018 12:55:00 Rectification Time: 14-11-2018 13:30:00 Time of Departure: 14-11-2018 13:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: lift 2 is out of order,

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Doors timed out, obstructed by passenger moving goods on level 2\r\nreset controls\r\nchecked opeartion ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle