



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Barristers Chambers 205 William St
205 William St Melbourne
Contract No: P3207

Callouts: 22271

Date of Call: 13-11-2018 14:37:23
Time of Arrival: 13-11-2018 14:55:00
Rectification Time: 13-11-2018 15:40:00
Time of Departure: 13-11-2018 15:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 4

For Floor(s): ground floor

Call Description: ground floor button is not lighting up in the lift

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: ground floor button in car 4 not lighting up when pushed, \r\nreplaced button contact block \r\nchecked operation ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

abbey