



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

1 Powlett Street
1 Powlett Street East Melbourne
Contract No: P3609

Callouts: 22280

Date of Call: 14-11-2018 8:54:00
Time of Arrival: 14-11-2018 9:20:00
Rectification Time: 14-11-2018 9:40:00
Time of Departure: 14-11-2018 10:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: out of order

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Fault log showed motor timeout fault. Reset controller. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*