



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Eden Apartments
1 Acacia Place Abbotsford
Contract No: P3453

Callouts:

Date of Call: 16-11-2018 18:46:00
Time of Arrival: 17-11-2018 1:05:00
Rectification Time: 17-11-2018 1:30:00
Time of Departure: 17-11-2018 1:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): ground

Call Description: reported doors are stuck open after doors where forced.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: door operator fault on ground floor,\r\nreset car door controller \r\nchecked landing door locks ok \r\nlift back in service.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

rob