



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 39, Melbourne
39 Queen St Melbourne
Contract No: P3542

Callouts:

Date of Call: 19-11-2018 10:30:00
Time of Arrival: 19-11-2018 10:30:00
Rectification Time: 19-11-2018 16:00:00
Time of Departure: 19-11-2018 16:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

For Lift(s): 1

For Floor(s): .

Call Description: working on lift 1 flood damage items replacing parts.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: replaced parts in lift 1 due to water damage.

Part Required: 1 memco car door sensor unit.

Service Technician

Robert Pelle

Report Customer

.