



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Potter Street 12-16, Dandenong
12-16 Potter Street Dandenong
Contract No: P3646

Maintenance:

Date of Call: 26-11-2018
Time of Arrival: 10:30:00
Time of Departure: 11:15:00

Maintenance Details

Maintenance Description: Phone works but operator found it hard to hear due to concrete grinding works in the building.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check all safety switches, limits in lift well	Y
check brake operation rope brake and associated equipment	Y
Check pit equipment and check water for pit	Y
Check trailer flexes, attachments running clearance	Y
Fire Service Operation Test	Y
Test Emergency Light Unit	Y
Pit Clean Report	Y

Service Technician

Kevin Wilkins

Customer Email